

FM Zulassung

Rohrschlaufe Typ EHS

gültig für

Rohrschlaufe Typ EHS

**Dieses Dokument der MÜPRO dient nur zur Information und unterliegt nicht dem Änderungsdienst.
Der gesamte Inhalt darf für werbliche oder andere Zwecke nur nach Genehmigung durch die MÜPRO verwendet werden.
Alle Rechte und Änderungen vorbehalten.**



Certificate of Compliance

This certificate is issued for the following:

Pipe Hanger Components for Automatic Sprinkler Systems

<i>Product Designation</i>	<i>Hanger Rod Size, in. (mm)</i>	<i>Component Description</i>	<i>For Nominal Pipe Sizes, in.</i>
EHS	3/8 (10)	Swivel Loop Hanger	1, 1-1/4, 1-1/2, 2, 2-1/2, 3, 4
EHS	1/2 (12)	Swivel Loop Hanger	5, 6
EHS	5/8 (16)	Swivel Loop Hanger	8

Prepared for:

Müpro Services GmbH
Hessenstrasse 11
65719 Hofheim-Wallau
Germany

FM Approvals Class: 1951, dated April 2008

Approval Identification: PR451565 Approval Granted: November 8, 2018

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

A handwritten signature in dark ink, appearing to read 'D.B. Fuller', written over a horizontal line.

David B. Fuller
VP, Manager-Fire Protection
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062



Member of the FM Global Group